

# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:



## Laboratory and Equipment

Laboratory Owner and Location  
Goniospectrometer System and Type  
Sensor Name, Calibr. Date and Serial No.  
Spectrometer Manufacturer and Model

Viso Systems, Copenhagen V, Denmark  
LabSpion – Type C, horizontal  
LabSensor Model2 – 11-1-2024 – 3130191315  
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

## Measurement Conditions

Number of C-planes and Resolution  
 $\gamma$  (gamma)-Resolution  
Test Distance  
Input Power, Power and Displ. Factors  
Input RMS Voltage and Current  
Frequency of Input Power  
Warm-up Time and Variation

12 planes – 30°  
5°  
12,10 m  
77,4 W – PF 0,98 – DPF 0,98  
230 V – 0,343 A  
50 Hz  
Lamp stabilized in 15 min 1 sec – 2,0%

## Tested Light Source



Product Name  
Item No. and Manufacturer  
Product Description (line 1)

813796-6500K  
813796-6500K – Dutchfulfillment  
LICHTLIJN MODULE | JUPITER | 65-80W | 120° | CCT-SWITCH

## Main Light Measurement Results

Output – Total Lumen (Up% / Down%)  
Efficiency  
Peak Intensity and Beam Angle  
Correlated Color Temperature, Target/Measured  
Color Rendering Index  
Color Rendering TM30-18  
Color Shift, CIE duv and MacAdam Steps  
Flicker

12187 lm – 0,96% / 99,04%  
157 lm/W  
4363 cd – 111,4°  
CCT = 6500 K / 6417 K  
CRI 84,1  
 $R_f$  83,7 –  $R_g$  96,4  
Duv 0,0079 – SDCM 10,6  
SVM n/a – PstLM n/a



# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS


Measurement tracking No. and Link: [VT250903-006229](https://vt250903-006229)

Operator:



## Luminous Intensity diagram

Unit: 0-100% of peak intensity



### Main Values

Output (total Lumen)	12187 lm
Lumen Up% / Down%	0,96% / 99,04%
Peak Intensity	4363 cd
Beam Angle (50%)	111,4°
Beam Angle (90%)	111,4°
Beam Angle (10%)	111,4°

### Cut-off Angle

Average 2,5%	171,6°
--------------	--------

### Field Angle

Average 10%	155,4°
-------------	--------


### Intensity Ratio

In 120° cone	81,4%
In 90° cone	55,7%

**C000-C180**

**C090-C270**

## Linear distribution diagram - Intensity (candela) vs $\gamma$ -angle



# Light Measurement Report

Print date: 5-9-2025


Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:



## Iso-intensity Diagram (Iso-candela)




90 %	3926,6 cd
80 %	3490,3 cd
70 %	3054,0 cd
60 %	2617,7 cd
50 %	2181,4 cd
40 %	1745,2 cd
30 %	1308,9 cd
20 %	872,6 cd
10 %	436,3 cd

Peak intensity: 4362,9 cd

Number of c-planes: 12

## Iso-illuminance Diagram (Iso-lux)



50,0 %	242,4 lx
30,0 %	145,4 lx
10,0 %	48,5 lx
5,0 %	24,2 lx
3,0 %	14,5 lx

Peak illuminance: 484,8 lx

Mounting height: 3,0 m

Number of c-planes: 12

# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:




## Color details


Correlated Color Temperature, Target CCT = 6500 K  
 Correlated Color Temperature, Measured CCT = 6417 K  
 Color Rendering Index CRI 84,1  
 Color Rendering Index, R9 (red component) R9 = 37,4  
 Color Rendering TM30-18 R<sub>f</sub> 83,7 – R<sub>g</sub> 96,4  
 Color Quality Scale CQS = 83,4

MacAdam Steps SDCM = 10,6  
 Color coordinates CIE 1931 (x;y) = (0,314;0,324)  
 Color coordinate CIEs 1960 (u;v) = (0,200;0,310)  
 Color deviation from BBL Duv = 0,0079  
 Color coordinate CIEs 1976 (CIELUV) (u';v') = (0,200;0,466)


### CIE 1931



### CIE 1931 – zoomed on Planckian locus




### Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
83,3	85,4	84,7	84,6	82,1	79,4	92,1	81,2	37,4	63,4	82,0	49,5	83,4	91,3	81,2

### Spectral power distribution (SPD) / W/nm – 0-100%




### TM30-18 R<sub>f</sub>-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
81,6	87,9	82,6	85,0	85,6	92,6	93,1	85,9	83,5	69,8	72,1	86,8	88,3	86,2	75,6	87,3

### Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
88,8	98,0	74,8	70,8	78,8	82,0	85,7	91,5	93,1	84,8	83,6	85,9	87,8	81,7	84,2

# Light Measurement Report

Print date: 5-9-2025


Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](https://www.viso-systems.com/VT250903-006229)

Operator:



## Beam Details



### Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3,3	6,6	9,8	13,1	16,4	19,7	23	26,2	29,5	32,8	36,1	39,4	42,7	45,9	49,2	52,5	55,8	59,1	62,3	65,6	ft
4363	1091	485	273	175	121	89	68	54	44	36	30	26	22	19	17	15	13	12	11	lux
405,3	101,3	45	25,3	16,2	11,3	8,3	6,3	5	4,1	3,3	2,8	2,4	2,1	1,8	1,6	1,4	1,3	1,1	1	fc

### Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
4363	4346	4296	4212	4089	3932	3744	3522	3264	2971	2632	2239	1792	1345	978	629	327	134	38	16	cd
100%	100%	98%	97%	94%	90%	86%	81%	75%	68%	60%	51%	41%	31%	22%	14%	7%	3%	1%	0%	of 0°val

### Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
4363	4346	4296	4212	4089	3932	3744	3522	3264	2971	2632	2239	1792	1345	978	629	327	134	38	16	cd
100%	100%	98%	97%	94%	90%	86%	81%	75%	68%	60%	51%	41%	31%	22%	14%	7%	3%	1%	0%	of 0°val

### Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
4363	4346	4296	4212	4089	3932	3744	3522	3264	2971	2632	2239	1792	1345	978	629	327	134	38	16	cd
100%	100%	98%	97%	94%	90%	86%	81%	75%	68%	60%	51%	41%	31%	22%	14%	7%	3%	1%	0%	of 0°val

### Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
4363	4346	4296	4212	4089	3932	3744	3522	3264	2971	2632	2239	1792	1345	978	629	327	134	38	16	cd
100%	100%	98%	97%	94%	90%	86%	81%	75%	68%	60%	51%	41%	31%	22%	14%	7%	3%	1%	0%	of 0°val

# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:



## Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances		70	70	50	50	30	70	70	50	50	30
	ρ Ceiling	70	70	50	50	30	70	70	50	50	30
	ρ Walls	50	30	50	30	30	50	30	50	30	30
	ρ Floor	20	20	20	20	20	20	20	20	20	20
Room size		Viewed Crosswise					Viewed Endwise				
H = mounting height above eye level		(Viewing direction orthogonal to lamp length axis)					(Viewing direction parallel to lamp length axis)				
X	Y										
2H	2H	26,8	28,0	27,1	28,3	28,6	27,2	28,4	27,5	28,7	28,9
	3H	27,8	29,0	28,2	29,3	29,5	28,3	29,5	28,7	29,8	30,0
	4H	28,2	29,3	28,6	29,6	29,9	28,7	29,9	29,2	30,2	30,5
	6H	28,4	29,4	28,7	29,7	30,1	29,1	30,1	29,4	30,4	30,8
	8H	28,4	29,4	28,8	29,7	30,2	29,1	30,1	29,5	30,4	30,9
	12H	28,4	29,4	28,8	29,7	30,2	29,1	30,1	29,5	30,5	30,9
4H	2H	27,3	28,5	27,7	28,8	29,0	27,6	28,8	28,0	29,1	29,3
	3H	28,6	29,5	29,0	29,9	30,4	29,0	30,0	29,4	30,3	30,8
	4H	28,9	29,8	29,4	30,3	30,8	29,5	30,4	29,9	30,8	31,3
	6H	29,2	30,0	29,7	30,4	30,8	29,8	30,6	30,3	31,0	31,4
	8H	29,3	30,0	29,8	30,4	30,8	29,9	30,7	30,4	31,0	31,4
	12H	29,3	29,9	29,8	30,3	30,8	29,9	30,6	30,5	31,0	31,5
8H	4H	29,1	29,9	29,6	30,3	30,7	29,6	30,4	30,1	30,7	31,1
	6H	29,5	30,0	30,0	30,5	31,1	30,0	30,6	30,5	31,1	31,6
	8H	29,6	30,1	30,1	30,6	31,3	30,2	30,7	30,7	31,2	31,9
	12H	29,6	30,1	30,2	30,6	31,2	30,3	30,7	30,9	31,2	31,9
12H	4H	29,1	29,7	29,6	30,2	30,7	29,6	30,2	30,1	30,6	31,1
	6H	29,5	30,0	30,0	30,5	31,2	30,1	30,6	30,6	31,1	31,7
	8H	29,6	30,0	30,2	30,6	31,2	30,2	30,6	30,8	31,2	31,8

### Variations with the observer position for the luminaire spacings, S:

S = 1.0H	0,1 / -0,2	0,1 / -0,1
S = 1.5H	0,4 / -0,5	0,3 / -0,4
S = 2.0H	0,8 / -1,0	0,8 / -1,0

## Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio)																	
	Room Values are expressed as percentage of Lumen delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	106	106	106	101	101	101	99	
1	109	105	100	97	106	102	99	95	98	95	92	94	91	89	90	88	86	84
2	99	92	85	79	97	90	84	78	86	81	76	83	78	75	79	76	73	71
3	91	81	73	66	88	79	72	66	76	70	64	73	68	63	70	66	62	60
4	83	72	63	56	81	70	62	56	68	61	55	65	59	54	63	58	53	51
5	77	64	55	49	74	63	54	48	61	53	48	58	52	47	57	51	46	44
6	71	58	49	42	69	57	48	42	55	47	42	53	46	41	51	45	41	39
7	66	52	44	37	64	51	43	37	50	42	37	48	42	37	47	41	36	34
8	61	48	39	33	59	47	39	33	45	38	33	44	38	33	43	37	32	31
9	57	44	36	30	56	43	35	30	42	35	30	41	34	30	40	34	29	27
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25

# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](https://www.viso-systems.com/VT250903-006229)


Operator:



## Luminaire budgetary diagram

Uncorrected, comprehensive UGR table according to 117-1995

LAMPS (number of lamps)



### Conditions

H = Room height	Flux = 12187 lm			
H <sub>down</sub> = Lamp distance from ceiling =	0.00 m	Line type	Ceiling reflectance	ρ(%) Wall reflectance
H <sub>work</sub> = Work area height from floor =	0.00 m	-----	70	50
E <sub>work</sub> = Average lux on work area =	100 lx	_____	50	30
				Floor reflectance
				20

### Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
414 lm	1191 lm	1816 lm	2207 lm	2295 lm	2001 lm	1333 lm	666 lm	148 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
17,1 lm	15,5 lm	16,9 lm	16,8 lm	15,6 lm	14,1 lm	11,1 lm	7,04 lm	2,49 lm

# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:



## Outdoor Light Planning

### Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	414 lm	3,4%
10-20°	1191 lm	9,8%
20-30°	1816 lm	14,9%
30-40°	2207 lm	18,1%
40-50°	2295 lm	18,8%
50-60°	2001 lm	16,4%
60-70°	1333 lm	10,9%
70-80°	666 lm	5,5%
80-90°	148 lm	1,2%
90-100°	17 lm	0,1%
100-110°	16 lm	0,1%
110-120°	17 lm	0,1%
120-130°	17 lm	0,1%
130-140°	16 lm	0,1%
140-150°	14 lm	0,1%
150-160°	11 lm	0,1%
160-170°	7 lm	0,1%
170-180°	2 lm	0,0%
<b>Total</b>	<b>12187 lm</b>	<b>100,0%</b>

### Intensity peaks

Max intensity	4363 cd
Intensity, 90°	38 cd
Intensity, 0°	4363 cd

### Zonal Lumen summary


Zone (γ)	Lumen	% Total
0-30°	3421 lm	28,1%
0-40°	5628 lm	46,2%
0-60°	9924 lm	81,4%
60-90°	2146 lm	17,6%
70-100°	831 lm	6,8%
90-120°	50 lm	0,4%
0-90°	12070 lm	99,0%
90-180°	117 lm	1,0%
0-180°	12187 lm	100,0%

### BUG rating

	Lumen	% Total
<b>Forward light</b>		
Low(0-30°)	1707 lm	14,0%
Medium(30-60°)	3242 lm	26,6%
High(60-80°)	1004 lm	8,2%
Very high(80-90°)	80 lm	0,7%
<b>Back light</b>		
Low(0-30°)	1707 lm	14,0%
Medium(30-60°)	3242 lm	26,6%
High(60-80°)	1004 lm	8,2%
Very high(80-90°)	80 lm	0,7%
<b>Uplight</b>		
Low(90-100°)	20 lm	0,2%
High(100-180°)	100 lm	0,8%

## IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

**BUG rating B3 U3 G1**



# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](https://www.viso-systems.com/VT250903-006229)

Operator:




## Power Details


### Input Power

Power feed to light source	77,4 W
Frequency of input power	50 Hz
RMS Input voltage feed, $V_{RMS}$	230 V
RMS Input current feed, $I_{RMS}$	0,343 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	78,84 VA
Displacement factor of AC power feed	0,98
Power factor of AC current feed	0,98
Total harmonic distortion of the current	7,19%
Total harmonic distortion of the voltage	0,06%

### Input Power Curve



### Efficiency



## Stabilization Details

### Warmup Conditions

Stable period	15 min
Stable change max	2,0%
Minimum time	15 min

### Color Temperature Change

CCT start	6498 K
CCT shift	+2 K
CCT end	6500 K


### Warmup Result

Total warmup time	Lamp stabilized in 15 min 1 sec
Warmup variation	-0,1%

### Output Change

Output start	12191 lm
Output change	-5 lm
Output end	12187 lm

### Stabilization Curve



# Light Measurement Report

Print date: 5-9-2025

Measurement date and time: 3-9-2025 16:35:33 – Measurement no. VFR-250903-2913-MS

Measurement tracking No. and Link: [VT250903-006229](#)

Operator:



## Flicker /TLA details

Flicker Meter Type Viso Systems LabFlicker  
 Frequency of input power 50 Hz  
 Flicker/TLA sample rate n/a samples/s

**Measurement time**  
 PstLM 180 sec  
 All other indices 1,2 sec

### Flicker indices according to Illuminating Engineering Society (IES)

Flicker frequency n/a Hz  
 Percent Flicker n/a %  
 Flicker index n/a

### Flicker indices according to California Energy Commission (CEC) 2016b

JA8/10 40 Hz n/a %  
 JA8/10 90 Hz n/a %  
 JA8/10 200 Hz n/a %  
 JA8/10 400 Hz n/a %  
 JA8/10 1000 Hz n/a %

### TLA indices (re IEC TR 61547-1, IEC 61000-3-3 and IEC 61000-4-15)

PstLM value (F < 80 Hz) n/a  
 SVM value (80 < F < 2000 Hz) n/a

### Flicker indices according to Lighting Research Center (2015)

Perception metric, Assist Mp n/a

### Flicker frame (frame of one flicker period in time domain)



### Flicker FFT (flicker curve in frequency domain)



### IEEE 1789 Frequency/modulation plot

