

# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Laboratory and Equipment

Laboratory Owner and Location  
Goniospectrometer System and Type  
Sensor Name, Calibr. Date and Serial No.  
Spectrometer Manufacturer and Model

Viso Systems, Copenhagen V, Denmark  
LabSpion – Type C, horizontal  
LabSensor Model2 – 11-1-2024 – 3130191315  
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

## Measurement Conditions

Number of C-planes and Resolution  
 $\gamma$  (gamma)-Resolution  
Test Distance  
Input Power, Power and Displ. Factors  
Input RMS Voltage and Current  
Frequency of Input Power  
Warm-up Time and Variation

12 planes – 30°  
5°  
12,10 m  
73,0 W – PF 0,98 – DPF 0,99  
230 V – 0,322 A  
50 Hz  
Lamp stabilized in 15 min 1 sec – 2,0%

## Tested Light Source



Product Name  
Item No. and Manufacturer  
Product Description (line 1)

813680-5700K  
813680-5700K – Dutchfulfillment  
LICHTLIJN MODULE | TITAN | 65-80W | 90° | 5700K

## Main Light Measurement Results

Output – Total Lumen (Up% / Down%)  
Efficiency  
Peak Intensity and Beam Angle  
Correlated Color Temperature, Target/Measured  
Color Rendering Index  
Color Rendering TM30-18  
Color Shift, CIE duv and MacAdam Steps  
Flicker

12898 lm – 2,61% / 97,39%  
177 lm/W  
9044 cd – 73,4°  
CCT = 5700 K / 5481 K  
CRI 81,8  
 $R_f$  81,4 –  $R_g$  96,7  
Duv 0,0036 – SDCM 5,7  
SVM 0,01 – PstLM 0,03



# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS


Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Luminous Intensity diagram

Unit: 0-100% of peak intensity



## Main Values

Output (total Lumen)	12898 lm
Lumen Up% / Down%	2,61% / 97,39%
Peak Intensity	9044 cd
Beam Angle (50%)	73,4°
Beam Angle (90%)	73,4°
Beam Angle (10%)	73,4°

## Cut-off Angle

Average 2,5%	146,3°
--------------	--------

## Field Angle

Average 10%	104,7°
-------------	--------


## Intensity Ratio

In 120° cone	92,0%
In 90° cone	82,2%

**C000-C180**

**C090-C270**

## Linear distribution diagram - Intensity (candela) vs $\gamma$ -angle



# Light Measurement Report

Print date: 11-9-2025


Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Iso-intensity Diagram (Iso-candela)




90 %	8139,3 cd
80 %	7234,9 cd
70 %	6330,6 cd
60 %	5426,2 cd
50 %	4521,8 cd
40 %	3617,5 cd
30 %	2713,1 cd
20 %	1808,7 cd
10 %	904,4 cd

Peak intensity: 9043,7 cd

Number of c-planes: 12

## Iso-illuminance Diagram (Iso-lux)



50,0 %	502,4 lx
30,0 %	301,5 lx
10,0 %	100,5 lx
5,0 %	50,2 lx
3,0 %	30,1 lx

Peak illuminance: 1004,9 lx

Mounting height: 3,0 m

Number of c-planes: 12

# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](https://www.viso-systems.com/VT250911-005178)

Operator:




## Color details


Correlated Color Temperature, Target CCT = 5700 K  
 Correlated Color Temperature, Measured CCT = 5481 K  
 Color Rendering Index CRI 81,8  
 Color Rendering Index, R9 (red component) R9 = 21,2  
 Color Rendering TM30-18 R<sub>f</sub> 81,4 – R<sub>g</sub> 96,7  
 Color Quality Scale CQS = 79,6

MacAdam Steps SDCM = 5,7  
 Color coordinates CIE 1931 (x;y) = (0,328;0,337)  
 Color coordinate CIEs 1960 (u;v) = (0,205;0,317)  
 Color deviation from BBL Duv = 0,0036  
 Color coordinate CIEs 1976 (CIELUV) (u';v') = (0,205;0,475)


### CIE 1931



### CIE 1931 – zoomed on Planckian locus




### Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
81,4	84,5	84,6	82,8	80,4	77,8	88,8	74,4	21,2	60,9	80,6	49,5	81,9	91,1	78,0

### Spectral power distribution (SPD) / W/nm – 0-100%




### TM30-18 R<sub>f</sub>-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
78,2	84,4	77,0	82,4	84,5	91,2	91,7	85,7	82,7	69,4	67,4	83,8	86,6	84,1	74,6	86,1

### Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
86,0	96,9	70,0	66,5	75,8	79,8	83,3	89,5	92,1	81,1	78,5	80,4	82,7	75,1	78,9

# Light Measurement Report

Print date: 11-9-2025


Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](https://www.viso-systems.com/VT250911-005178)

Operator:



## Beam Details



### Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3,3	6,6	9,8	13,1	16,4	19,7	23	26,2	29,5	32,8	36,1	39,4	42,7	45,9	49,2	52,5	55,8	59,1	62,3	65,6	ft
9044	2261	1005	565	362	251	185	141	112	90	75	63	54	46	40	35	31	28	25	23	lux
840,2	210	93,4	52,5	33,6	23,3	17,1	13,1	10,4	8,4	6,9	5,8	5	4,3	3,7	3,3	2,9	2,6	2,3	2,1	fc

### Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
9044	8951	8685	8286	7783	7155	6276	5020	3493	2100	1192	733	505	372	277	202	144	101	76	66	cd
100%	99%	96%	92%	86%	79%	69%	56%	39%	23%	13%	8%	6%	4%	3%	2%	2%	1%	1%	1%	of 0°val

### Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
9044	8951	8685	8286	7783	7155	6276	5020	3493	2100	1192	733	505	372	277	202	144	101	76	66	cd
100%	99%	96%	92%	86%	79%	69%	56%	39%	23%	13%	8%	6%	4%	3%	2%	2%	1%	1%	1%	of 0°val

### Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
9044	8951	8685	8286	7783	7155	6276	5020	3493	2100	1192	733	505	372	277	202	144	101	76	66	cd
100%	99%	96%	92%	86%	79%	69%	56%	39%	23%	13%	8%	6%	4%	3%	2%	2%	1%	1%	1%	of 0°val

### Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
9044	8951	8685	8286	7783	7155	6276	5020	3493	2100	1192	733	505	372	277	202	144	101	76	66	cd
100%	99%	96%	92%	86%	79%	69%	56%	39%	23%	13%	8%	6%	4%	3%	2%	2%	1%	1%	1%	of 0°val

# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances		70	70	50	50	30	70	70	50	50	30
	ρ Ceiling	70	70	50	50	30	70	70	50	50	30
	ρ Walls	50	30	50	30	30	50	30	50	30	30
	ρ Floor	20	20	20	20	20	20	20	20	20	20
Room size		Viewed Crosswise					Viewed Endwise				
H = mounting height above eye level		(Viewing direction orthogonal to lamp length axis)					(Viewing direction parallel to lamp length axis)				
X	Y										
2H	2H	20,7	21,5	20,9	21,8	22,0	20,8	21,6	21,0	21,9	22,2
	3H	20,8	21,7	21,2	22,0	22,2	20,9	21,9	21,4	22,1	22,4
	4H	20,9	21,8	21,3	22,1	22,4	21,1	22,0	21,5	22,3	22,6
	6H	21,1	21,8	21,4	22,2	22,6	21,3	22,1	21,7	22,4	22,8
	8H	21,1	21,9	21,5	22,2	22,7	21,4	22,2	21,8	22,5	23,0
	12H	21,2	21,9	21,6	22,3	22,7	21,5	22,2	21,9	22,6	23,1
4H	2H	20,5	21,4	21,0	21,7	22,0	20,7	21,6	21,1	21,9	22,1
	3H	21,0	21,7	21,4	22,1	22,5	21,1	21,9	21,5	22,2	22,7
	4H	21,1	21,8	21,6	22,2	22,8	21,3	22,0	21,8	22,4	23,0
	6H	21,3	22,0	21,9	22,4	22,8	21,6	22,3	22,1	22,6	23,1
	8H	21,5	22,0	22,0	22,4	22,9	21,8	22,4	22,3	22,8	23,2
	12H	21,6	22,0	22,1	22,5	23,0	21,9	22,4	22,5	22,9	23,4
8H	4H	21,2	21,8	21,7	22,2	22,6	21,4	22,0	21,9	22,4	22,8
	6H	21,5	21,9	22,1	22,4	23,0	21,8	22,2	22,3	22,7	23,3
	8H	21,7	22,1	22,3	22,6	23,3	22,1	22,4	22,6	23,0	23,6
	12H	21,9	22,2	22,6	22,8	23,4	22,3	22,6	23,0	23,2	23,8
12H	4H	21,1	21,6	21,7	22,1	22,6	21,3	21,8	21,9	22,3	22,8
	6H	21,6	21,9	22,1	22,5	23,2	21,8	22,2	22,4	22,7	23,4
	8H	21,8	22,1	22,4	22,6	23,3	22,1	22,4	22,7	22,9	23,6

### Variations with the observer position for the luminaire spacings, S:

S = 1.0H	1,2 / -1,3	1,1 / -1,2
S = 1.5H	2,8 / -1,9	2,6 / -1,6
S = 2.0H	4,3 / -2,3	4,1 / -2,0

## Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio)																	
	Room Values are expressed as percentage of Lumen delivered to the task surface																	
0	118	118	118	118	115	115	115	115	110	110	104	104	104	100	100	100	97	
1	111	108	105	102	108	105	103	100	101	98	96	97	95	93	93	91	90	88
2	104	98	93	89	102	96	92	88	92	89	85	89	86	83	86	83	81	79
3	98	90	84	79	95	88	82	78	85	80	76	82	78	75	79	76	73	71
4	91	82	76	70	89	81	75	70	78	73	69	76	71	68	74	70	66	65
5	86	76	69	63	84	74	68	63	72	67	62	70	65	61	68	64	61	59
6	80	70	63	58	79	69	62	57	67	61	57	65	60	56	64	59	55	54
7	76	65	58	53	74	64	57	52	62	56	52	61	55	51	59	55	51	49
8	71	60	53	48	70	59	53	48	58	52	48	57	51	47	55	51	47	45
9	67	56	49	45	66	55	49	44	54	48	44	53	48	44	52	47	43	42
10	64	52	46	41	62	52	45	41	51	45	41	50	44	41	49	44	40	39

# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)


Operator:



## Luminaire budgetary diagram

Uncorrected, comprehensive UGR table according to 117-1995

LAMPS (number of lamps)



### Conditions

H = Room height	Flux = 12898 lm			
H <sub>down</sub> = Lamp distance from ceiling =	0.00 m			
H <sub>work</sub> = Work area height from floor =	0.00 m			
E <sub>work</sub> = Average lux on work area =	100 lx			
		ρ(%)		
		Ceiling reflectance	Wall reflectance	Floor reflectance
		-----	-----	-----
		70	50	30
		—————	—————	—————
		50	30	20

### Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
850 lm	2337 lm	3295 lm	3120 lm	1610 lm	657 lm	369 lm	214 lm	110 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
72,3 lm	63,5 lm	55,7 lm	46,6 lm	38,7 lm	28,3 lm	18,2 lm	10,3 lm	3,24 lm

# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Outdoor Light Planning

### Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	850 lm	6,6%
10-20°	2337 lm	18,1%
20-30°	3295 lm	25,5%
30-40°	3120 lm	24,2%
40-50°	1610 lm	12,5%
50-60°	657 lm	5,1%
60-70°	369 lm	2,9%
70-80°	214 lm	1,7%
80-90°	110 lm	0,9%
90-100°	72 lm	0,6%
100-110°	64 lm	0,5%
110-120°	56 lm	0,4%
120-130°	47 lm	0,4%
130-140°	39 lm	0,3%
140-150°	28 lm	0,2%
150-160°	18 lm	0,1%
160-170°	10 lm	0,1%
170-180°	3 lm	0,0%
<b>Total</b>	<b>12898 lm</b>	<b>100,0%</b>

### Intensity peaks

Max intensity	9044 cd
Intensity, 90°	76 cd
Intensity, 0°	9044 cd

### Zonal Lumen summary


Zone (γ)	Lumen	% Total
0-30°	6481 lm	50,3%
0-40°	9602 lm	74,4%
0-60°	11868 lm	92,0%
60-90°	693 lm	5,4%
70-100°	397 lm	3,1%
90-120°	191 lm	1,5%
0-90°	12561 lm	97,4%
90-180°	337 lm	2,6%
0-180°	12898 lm	100,0%

### BUG rating

	Lumen	% Total
<b>Forward light</b>		
Low(0-30°)	3223 lm	25,0%
Medium(30-60°)	2707 lm	21,0%
High(60-80°)	294 lm	2,3%
Very high(80-90°)	56 lm	0,4%
<b>Back light</b>		
Low(0-30°)	3223 lm	25,0%
Medium(30-60°)	2707 lm	21,0%
High(60-80°)	294 lm	2,3%
Very high(80-90°)	56 lm	0,4%
<b>Uplight</b>		
Low(90-100°)	73 lm	0,6%
High(100-180°)	264 lm	2,0%

## IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

**BUG rating B4 U3 G1**



# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:




## Power Details

### Input Power

Power feed to light source	73,0 W
Frequency of input power	50 Hz
RMS Input voltage feed, $V_{RMS}$	230 V
RMS Input current feed, $I_{RMS}$	0,322 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	74,19 VA
Displacement factor of AC power feed	0,99
Power factor of AC current feed	0,98
Total harmonic distortion of the current	4,8%
Total harmonic distortion of the voltage	0,06%

### Input Power Curve



### Efficiency

Radiated power efficiency 53,4%



Lumen efficiency 177 lm/W



## Stabilization Details

### Warmup Conditions

Stable period	15 min
Stable change max	2,0%
Minimum time	15 min

### Color Temperature Change

CCT start	5696 K
CCT shift	+4 K
CCT end	5700 K


### Warmup Result

Total warmup time	Lamp stabilized in 15 min 1 sec
Warmup variation	-0,2%

### Output Change

Output start	12913 lm
Output change	-15 lm
Output end	12898 lm

### Stabilization Curve



# Light Measurement Report

Print date: 11-9-2025

Measurement date and time: 11-9-2025 09:13:21 – Measurement no. VFR-250911-3078-MS

Measurement tracking No. and Link: [VT250911-005178](#)

Operator:



## Flicker /TLA details

Flicker Meter Type: Viso Systems LabFlicker  
 Frequency of input power: 50 Hz  
 Flicker/TLA sample rate: 20000 samples/s

**Measurement time**  
 PstLM: 180 sec  
 All other indices: 1,2 sec

### Flicker indices according to Illuminating Engineering Society (IES)

Flicker frequency: 102,04 Hz  
 Percent Flicker: 0,25 %  
 Flicker index: 0

### Flicker indices according to California Energy Commission (CEC) 2016b

JA8/10 40 Hz: 0,02 %  
 JA8/10 90 Hz: 0,03 %  
 JA8/10 200 Hz: 0,24 %  
 JA8/10 400 Hz: 0,23 %  
 JA8/10 1000 Hz: 0,24 %


### TLA indices (re IEC TR 61547-1, IEC 61000-3-3 and IEC 61000-4-15)

PstLM value (F < 80 Hz): 0,03  
 SVM value (80 < F < 2000 Hz): 0,01

### Flicker indices according to Lighting Research Center (2015)

Perception metric, Assist Mp: 0,02

### Flicker frame (frame of one flicker period in time domain)



### Flicker FFT (flicker curve in frequency domain)



### IEEE 1789 Frequency/modulation plot

