

Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:



Laboratory and Equipment

Laboratory Owner and Location
Goniospectrometer System and Type
Sensor Name, Calibr. Date and Serial No.
Spectrometer Manufacturer and Model

Viso Systems, Copenhagen V, Denmark
LabSpion – Type C, horizontal
LabSensor Model2 – 11-1-2024 – 3130191315
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

Measurement Conditions

Number of C-planes and Resolution
 γ (gamma)-Resolution
Test Distance
Input Power, Power and Displ. Factors
Input RMS Voltage and Current
Frequency of Input Power
Warm-up Time and Variation

16 planes – 22,5°
5°
12,09 m
72,1 W – PF 0,98 – DPF 0,98
230 V – 0,320 A
50 Hz
Lamp stabilized in 15 min 3 sec – 2,0%

Tested Light Source



Product Name
Item No. and Manufacturer
Product Description (line 1)

813710-3500K
813710-3500K – Dutchfulfillment
LICHTLIJN MODULE | TITAN | 65-80W | 90° | CCT-SWITCH

Main Light Measurement Results

Output – Total Lumen (Up% / Down%)
Efficiency
Peak Intensity and Beam Angle
Correlated Color Temperature, Target/Measured
Color Rendering Index
Color Rendering TM30-18
Color Shift, CIE duv and MacAdam Steps
Flicker

12464 lm – 2,36% / 97,64%
173 lm/W
6878 cd – 82,1°
CCT = 3376 K / 3376 K
CRI 81,6
 R_f 82,5 – R_g 97,6
Duv 0,0033 – SDCM n/a
SVM 0,01 – PstLM 0,02



Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS


Measurement tracking No. and Link: [n/a](#)

Operator:



Luminous Intensity diagram

Unit: 0-100% of peak intensity



Main Values

Output (total Lumen)	12464 lm
Lumen Up% / Down%	2,36% / 97,64%
Peak Intensity	6878 cd
Beam Angle (50%)	82,1°
Beam Angle (90%)	78,4°
Beam Angle (10%)	84,7°

Cut-off Angle

Average 2,5%	156,1°
--------------	--------

Field Angle

Average 10%	125,4°
-------------	--------


Intensity Ratio

In 120° cone	90,5%
In 90° cone	72,7%

C000-C180

C090-C270

Linear distribution diagram - Intensity (candela) vs γ -angle



Light Measurement Report

Print date: 3-9-2025


Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:



Iso-intensity Diagram (Iso-candela)




90 %	6186,3 cd
80 %	5499,0 cd
70 %	4811,6 cd
60 %	4124,2 cd
50 %	3436,9 cd
40 %	2749,5 cd
30 %	2062,1 cd
20 %	1374,7 cd
10 %	687,4 cd

Peak intensity: 6873,7 cd

Number of c-planes: 16

Iso-illuminance Diagram (Iso-lux)



50,0 %	375,6 lx
30,0 %	225,3 lx
10,0 %	75,1 lx
5,0 %	37,6 lx
3,0 %	22,5 lx

Peak illuminance: 751,1 lx

Mounting height: 3,0 m

Number of c-planes: 16

Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:




Color details


Correlated Color Temperature, Target CCT = 3376 K
 Correlated Color Temperature, Measured CCT = 3376 K
 Color Rendering Index CRI 81,6
 Color Rendering Index, R9 (red component) R9 = 18,0
 Color Rendering TM30-18 R_f 82,5 – R_g 97,6
 Color Quality Scale CQS = 81,4

MacAdam Steps SDCM = n/a
 Color coordinates CIE 1931 (x;y) = (0,416;0,404)
 Color coordinate CIEs 1960 (u;v) = (0,238;0,345)
 Color deviation from BBL Duv = 0,0033
 Color coordinate CIEs 1976 (CIELUV) (u';v') = (0,238;0,518)


CIE 1931



CIE 1931 – zoomed on Planckian locus




Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
80,7	85,5	88,8	82,2	78,7	79,9	88,2	68,4	18,0	64,3	79,7	51,6	81,1	92,9	75,1

Spectral power distribution (SPD) / W/nm – 0-100%




TM30-18 Rf-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
81,2	82,6	75,4	83,8	88,5	89,7	88,8	90,5	87,7	75,7	71,1	83,0	87,9	82,0	80,7	78,7

Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
81,1	97,0	75,1	73,7	79,3	79,8	81,0	87,1	94,8	85,4	84,0	84,3	85,0	75,0	76,7

Light Measurement Report

Print date: 3-9-2025


Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:



Beam Details



Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3,3	6,6	9,8	13,1	16,4	19,7	23	26,2	29,5	32,8	36,1	39,4	42,7	45,9	49,2	52,5	55,8	59,1	62,3	65,6	ft
6746	1687	750	422	270	187	138	105	83	67	56	47	40	34	30	26	23	21	19	17	lux
626,7	156,7	69,6	39,2	25,1	17,4	12,8	9,8	7,7	6,3	5,2	4,4	3,7	3,2	2,8	2,4	2,2	1,9	1,7	1,6	fc

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
6746	6790	6849	6806	6573	6130	5488	4699	3844	3000	2261	1652	1121	683	393	224	118	54	22	16	cd
100%	101%	102%	101%	97%	91%	81%	70%	57%	44%	34%	24%	17%	10%	6%	3%	2%	1%	0%	0%	of 0°val

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
6746	6716	6569	6276	5846	5281	4629	3954	3260	2518	1770	1129	688	438	300	212	147	100	76	68	cd
100%	100%	97%	93%	87%	78%	69%	59%	48%	37%	26%	17%	10%	6%	4%	3%	2%	1%	1%	1%	of 0°val

Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
6746	6790	6849	6806	6573	6130	5488	4699	3844	3000	2261	1652	1121	683	393	224	118	54	22	16	cd
100%	101%	102%	101%	97%	91%	81%	70%	57%	44%	34%	24%	17%	10%	6%	3%	2%	1%	0%	0%	of 0°val

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
6746	6716	6569	6276	5846	5281	4629	3954	3260	2518	1770	1129	688	438	300	212	147	100	76	68	cd
100%	100%	97%	93%	87%	78%	69%	59%	48%	37%	26%	17%	10%	6%	4%	3%	2%	1%	1%	1%	of 0°val

Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)


Operator:



Luminaire budgetary diagram

Uncorrected, comprehensive UGR table according to 117-1995

LAMPS (number of lamps)



Conditions

H = Room height	Flux = 12464 lm			
H _{down} = Lamp distance from ceiling =	0.00 m	Line type	Ceiling reflectance	ρ(%) Wall reflectance
H _{work} = Work area height from floor =	0.00 m	-----	70	50
E _{work} = Average lux on work area =	100 lx	_____	50	30
				Floor reflectance
				20

Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
645 lm	1857 lm	2658 lm	2722 lm	2140 lm	1257 lm	558 lm	238 lm	96,1 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
55,4 lm	53,2 lm	50,5 lm	43,4 lm	34,7 lm	26,1 lm	17,4 lm	9,71 lm	3,04 lm

Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:



Outdoor Light Planning

Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	645 lm	5,2%
10-20°	1857 lm	14,9%
20-30°	2658 lm	21,3%
30-40°	2722 lm	21,8%
40-50°	2140 lm	17,2%
50-60°	1257 lm	10,1%
60-70°	558 lm	4,5%
70-80°	238 lm	1,9%
80-90°	96 lm	0,8%
90-100°	55 lm	0,4%
100-110°	53 lm	0,4%
110-120°	50 lm	0,4%
120-130°	43 lm	0,3%
130-140°	35 lm	0,3%
140-150°	26 lm	0,2%
150-160°	17 lm	0,1%
160-170°	10 lm	0,1%
170-180°	3 lm	0,0%
Total	12464 lm	100,0%

Intensity peaks

Max intensity	6878 cd
Intensity, 90°	22 cd
Intensity, 0°	6746 cd

Zonal Lumen summary


Zone (γ)	Lumen	% Total
0-30°	5160 lm	41,4%
0-40°	7882 lm	63,2%
0-60°	11279 lm	90,5%
60-90°	892 lm	7,2%
70-100°	389 lm	3,1%
90-120°	159 lm	1,3%
0-90°	12171 lm	97,6%
90-180°	294 lm	2,4%
0-180°	12464 lm	100,0%

BUG rating

	Lumen	% Total
Forward light		
Low(0-30°)	2573 lm	20,6%
Medium(30-60°)	3060 lm	24,5%
High(60-80°)	403 lm	3,2%
Very high(80-90°)	49 lm	0,4%
Back light		
Low(0-30°)	2573 lm	20,6%
Medium(30-60°)	3060 lm	24,5%
High(60-80°)	403 lm	3,2%
Very high(80-90°)	49 lm	0,4%
Uplight		
Low(90-100°)	56 lm	0,4%
High(100-180°)	238 lm	1,9%

IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

BUG rating B4 U3 G1



Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:




Power Details

Input Power

Power feed to light source	72,1 W
Frequency of input power	50 Hz
RMS Input voltage feed, V_{RMS}	230 V
RMS Input current feed, I_{RMS}	0,320 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	73,53 VA
Displacement factor of AC power feed	0,98
Power factor of AC current feed	0,98
Total harmonic distortion of the current	6,7%
Total harmonic distortion of the voltage	0,07%

Input Power Curve



Efficiency

Radiated power efficiency	48,7%
Lumen efficiency	173 lm/W

Stabilization Details

Warmup Conditions

Stable period	15 min
Stable change max	2,0%
Minimum time	15 min

Color Temperature Change

CCT start	3380 K
CCT shift	-4 K
CCT end	3376 K


Warmup Result

Total warmup time	Lamp stabilized in 15 min 3 sec
Warmup variation	-0,8%

Output Change

Output start	12563 lm
Output change	-99 lm
Output end	12464 lm

Stabilization Curve



Light Measurement Report

Print date: 3-9-2025

Measurement date and time: 3-9-2025 09:55:36 – Measurement no. VFR-250903-2894-MS

Measurement tracking No. and Link: [n/a](#)

Operator:



Flicker /TLA details

Flicker Meter Type Viso Systems LabFlicker
 Frequency of input power 50 Hz
 Flicker/TLA sample rate 20000 samples/s

Measurement time
 PstLM 180 sec
 All other indices 1,2 sec

Flicker indices according to Illuminating Engineering Society (IES)

Flicker frequency 100,5 Hz
 Percent Flicker 0,35 %
 Flicker index 0

Flicker indices according to California Energy Commission (CEC) 2016b

JA8/10 40 Hz 0,02 %
 JA8/10 90 Hz 0,03 %
 JA8/10 200 Hz 0,33 %
 JA8/10 400 Hz 0,33 %
 JA8/10 1000 Hz 0,33 %


TLA indices (re IEC TR 61547-1, IEC 61000-3-3 and IEC 61000-4-15)

PstLM value (F < 80 Hz) 0,02
 SVM value (80 < F < 2000 Hz) 0,01

Flicker indices according to Lighting Research Center (2015)

Perception metric, Assist Mp 0,01

Flicker frame (frame of one flicker period in time domain)



Flicker FFT (flicker curve in frequency domain)



IEEE 1789 Frequency/modulation plot

