

# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](#)

Operator:



## Laboratory and Equipment

Laboratory Owner and Location  
Goniospectrometer System and Type  
Sensor Name, Calibr. Date and Serial No.  
Spectrometer Manufacturer and Model

Viso Systems, Copenhagen V, Denmark  
LabSpion – Type C, horizontal  
LabSensor Model2 – 11-1-2024 – 3130191315  
Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

## Measurement Conditions

Number of C-planes and Resolution  
 $\gamma$  (gamma)-Resolution  
Test Distance  
Input Power, Power and Displ. Factors  
Input RMS Voltage and Current  
Frequency of Input Power  
Warm-up Time and Variation

24 planes – 15°  
5°  
12,10 m  
20,8 W – PF 0,91 – DPF 0,99  
230 V – 0,099 A  
50 Hz  
Lamp stabilized in 15 min 3 sec – 2,0%

## Tested Light Source



Product Name  
Item No. and Manufacturer  
Product Description (line 1)

848063-6000K  
848063-6000K – Dutchfulfillment  
LED TL-BUIS | T8 | YMIR | 150CM | 22W

## Main Light Measurement Results

Output – Total Lumen (Up% / Down%)  
Efficiency  
Peak Intensity and Beam Angle  
Correlated Color Temperature, Target/Measured  
Color Rendering Index  
Color Rendering TM30-18  
Color Shift, CIE duv and MacAdam Steps  
Flicker

2842 lm – 26,67% / 73,33%  
137 lm/W  
455 cd – 174°  
CCT = 6000 K / 6650 K  
CRI 84,8  
 $R_f$  84,7 –  $R_g$  93,0  
Duv 0,0046 – SDCM 14,2  
SVM 0,05 – PstLM 0,01



# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS


Measurement tracking No. and Link: [VT250224-002255](#)

Operator:



## Luminous Intensity diagram

Unit: 0-100% of peak intensity



## Main Values

Output (total Lumen)	2842 lm
Lumen Up% / Down%	26,67% / 73,33%
Peak Intensity	455 cd
Beam Angle (50%)	174°
Beam Angle (90%)	174°
Beam Angle (10%)	174°

## Cut-off Angle

Average 2,5%	315,2°
--------------	--------

## Field Angle


Average 10%	289,4°
-------------	--------

## Intensity Ratio

In 120° cone	43,3%
In 90° cone	27,1%

**C000-C180**  
**C090-C270**

## Linear distribution diagram - Intensity (candela) vs $\gamma$ -angle



# Light Measurement Report

Print date: 24-2-2025


Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](https://vt250224-002255)

Operator:




## Iso-intensity Diagram (Iso-candela)



90 %	409,9 cd
80 %	364,4 cd
70 %	318,8 cd
60 %	273,3 cd
50 %	227,7 cd
40 %	182,2 cd
30 %	136,6 cd
20 %	91,1 cd
10 %	45,5 cd

Peak intensity: 455,5 cd  
Number of c-planes: 24

## Iso-illuminance Diagram (Iso-lux)



50,0 %	25,3 lx
30,0 %	15,2 lx
10,0 %	5,1 lx
5,0 %	2,5 lx
3,0 %	1,5 lx

Peak illuminance: 50,6 lx  
Mounting height: 3,0 m  
Number of c-planes: 24

# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](https://vt250224-002255)

Operator:




## Color details


Correlated Color Temperature, Target CCT = 6000 K  
 Correlated Color Temperature, Measured CCT = 6650 K  
 Color Rendering Index CRI 84,8  
 Color Rendering Index, R9 (red component) R9 = 13,0  
 Color Rendering TM30-18 R<sub>f</sub> 84,7 – R<sub>g</sub> 93,0  
 Color Quality Scale CQS = 83,6

MacAdam Steps SDCM = 14,2  
 Color coordinates CIE 1931 (x;y) = (0,322;0,332)  
 Color coordinate CIEs 1960 (u;v) = (0,203;0,314)  
 Color deviation from BBL Duv = 0,0046  
 Color coordinate CIEs 1976 (CIELUV) (u';v') = (0,203;0,471)


### CIE 1931



### CIE 1931 – zoomed on Planckian locus




### Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
82,4	90,1	94,3	82,7	82,6	85,6	89,4	71,4	13,0	76,2	82,4	58,7	85,0	97,3	76,4

### Spectral power distribution (SPD) / W/nm – 0-100%




### TM30-18 R<sub>f</sub>-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
77,2	85,1	86,0	90,5	88,5	93,0	92,3	85,2	84,1	76,9	78,3	92,8	86,7	83,0	71,6	85,6

### Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
82,3	98,0	82,4	76,2	80,5	82,2	85,9	90,3	97,5	91,2	87,8	86,7	85,7	73,1	77,2

# Light Measurement Report

Print date: 24-2-2025


Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](https://www.viso-systems.com/VT250224-002255)

Operator:



## Beam Details



### Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3,3	6,6	9,8	13,1	16,4	19,7	23	26,2	29,5	32,8	36,1	39,4	42,7	45,9	49,2	52,5	55,8	59,1	62,3	65,6	ft
455	114	51	28	18	13	9	7	6	5	4	3	3	2	2	2	2	1	1	1	lux
42,3	10,6	4,7	2,6	1,7	1,2	0,9	0,7	0,5	0,4	0,3	0,3	0,3	0,2	0,2	0,2	0,1	0,1	0,1	0,1	fc

### Intensities in 0° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°	γ
455	452	442	428	407	381	351	318	284	249	218	194	169	141	110	77	48	22	7	4	cd
100%	99%	97%	94%	89%	84%	77%	70%	62%	55%	48%	42%	37%	31%	24%	17%	10%	5%	1%	1%	of 0°val

### Intensities in 90° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°	γ
455	452	442	428	407	381	351	318	284	249	218	194	169	141	110	77	48	22	7	4	cd
100%	99%	97%	94%	89%	84%	77%	70%	62%	55%	48%	42%	37%	31%	24%	17%	10%	5%	1%	1%	of 0°val

### Intensities in 180° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°	γ
455	452	442	428	407	381	351	318	284	249	218	194	169	141	110	77	48	22	7	4	cd
100%	99%	97%	94%	89%	84%	77%	70%	62%	55%	48%	42%	37%	31%	24%	17%	10%	5%	1%	1%	of 0°val

### Intensities in 270° c-plane

0°	9°	18°	27°	36°	45°	54°	63°	72°	81°	90°	99°	108°	117°	126°	135°	144°	153°	162°	171°	γ
455	452	442	428	407	381	351	318	284	249	218	194	169	141	110	77	48	22	7	4	cd
100%	99%	97%	94%	89%	84%	77%	70%	62%	55%	48%	42%	37%	31%	24%	17%	10%	5%	1%	1%	of 0°val

# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](https://www.viso-systems.com/VT250224-002255)

Operator:



## Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances		70	70	50	50	30	70	70	50	50	30
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room size		Viewed Crosswise					Viewed Endwise				
H = mounting height above eye level		(Viewing direction orthogonal to lamp length axis)					(Viewing direction parallel to lamp length axis)				
X	Y										
2H	2H	20,0	21,1	20,6	21,8	22,6	19,0	20,2	19,7	20,8	21,6
	3H	22,6	23,7	23,4	24,4	25,1	21,3	22,4	22,0	23,0	23,8
	4H	24,1	25,1	24,8	25,8	26,6	22,4	23,5	23,1	24,1	24,9
	6H	25,8	26,7	26,5	27,4	28,2	23,6	24,5	24,3	25,3	26,1
	8H	26,7	27,6	27,4	28,3	29,2	24,2	25,2	24,9	25,8	26,7
	12H	27,7	28,7	28,4	29,3	30,2	24,8	25,8	25,5	26,4	27,3
4H	2H	20,6	21,7	21,4	22,4	23,1	19,9	21,0	20,7	21,7	22,4
	3H	23,5	24,5	24,2	25,1	26,0	22,4	23,4	23,1	24,0	24,9
	4H	25,0	26,2	25,8	26,7	27,6	23,6	24,8	24,4	25,3	26,2
	6H	26,8	27,6	27,6	28,4	29,2	25,0	25,8	25,7	26,5	27,3
	8H	27,8	28,5	28,6	29,3	30,1	25,6	26,3	26,4	27,1	27,9
	12H	29,0	29,5	29,7	30,3	31,2	26,3	26,9	27,0	27,7	28,5
8H	4H	25,4	26,1	26,2	26,9	27,7	24,3	25,0	25,1	25,7	26,6
	6H	27,4	28,0	28,2	28,8	29,7	25,8	26,4	26,6	27,2	28,1
	8H	28,5	29,0	29,4	29,9	30,9	26,6	27,1	27,4	28,0	29,0
	12H	29,8	30,3	30,7	31,1	32,1	27,4	27,9	28,3	28,7	29,7
12H	4H	25,5	26,1	26,3	26,9	27,8	24,4	25,0	25,2	25,8	26,7
	6H	27,5	28,0	28,4	28,9	29,9	26,1	26,6	26,9	27,4	28,4
	8H	28,7	29,2	29,6	30,0	31,0	27,0	27,4	27,8	28,3	29,2

### Variations with the observer position for the luminaire spacings, S:

S = 1.0H	0,1 / -0,1	0,1 / 0,0
S = 1.5H	0,1 / -0,1	0,1 / -0,1
S = 2.0H	0,3 / -0,3	0,1 / -0,2

## Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio)																	
	Room Values are expressed as percentage of Lumen delivered to the task surface																	
0	113	113	113	113	107	107	107	107	96	96	96	87	87	87	78	78	78	73
1	99	92	87	82	93	87	82	78	78	74	70	70	67	64	62	59	57	53
2	88	78	70	63	83	74	67	61	66	60	55	59	54	50	52	48	45	41
3	80	68	58	51	75	64	56	49	57	50	45	51	45	41	45	40	37	33
4	72	59	50	42	68	56	47	40	50	43	37	45	39	34	39	35	30	27
5	66	52	43	36	62	50	41	34	44	37	31	40	33	29	35	30	26	23
6	61	47	37	31	57	44	36	29	40	32	27	36	29	25	32	26	22	20
7	56	42	33	27	53	40	32	26	36	29	24	32	26	22	29	24	20	17
8	52	38	29	23	49	36	28	22	33	26	21	29	23	19	26	21	17	15
9	48	35	26	21	46	33	25	20	30	23	18	27	21	17	24	19	16	13
10	45	32	24	18	43	30	23	18	28	21	17	25	19	15	22	18	14	12

# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](#)


Operator:



## Luminaire budgetary diagram

Uncorrected, comprehensive UGR table according to 117-1995

LAMPS (number of lamps)



### Conditions

H = Room height	Flux = 2842 lm				
H <sub>down</sub> = Lamp distance from ceiling =	0.00 m	Line type	Ceiling reflectance	ρ(%) Wall reflectance	Floor reflectance
H <sub>work</sub> = Work area height from floor =	0.00 m	-----	70	50	30
E <sub>work</sub> = Average lux on work area =	100 lx	—————	50	30	20

### Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
43,3 lm	126 lm	199 lm	257 lm	295 lm	311 lm	308 lm	288 lm	256 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
223 lm	188 lm	147 lm	102 lm	60,3 lm	28,3 lm	8,19 lm	1,50 lm	0,389 lm

# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](#)


Operator:



Outdoor Light Planning			Zonal Lumen summary		
Zone (y)	Lumen	% Total	Zone (y)	Lumen	% Total
0-10°	43 lm	1,5%	0-30°	369 lm	13,0%
10-20°	126 lm	4,4%	0-40°	626 lm	22,0%
20-30°	199 lm	7,0%	0-60°	1232 lm	43,3%
30-40°	257 lm	9,0%	60-90°	852 lm	30,0%
40-50°	295 lm	10,4%	70-100°	767 lm	27,0%
50-60°	311 lm	11,0%	90-120°	557 lm	19,6%
60-70°	308 lm	10,8%	0-90°	2084 lm	73,3%
70-80°	288 lm	10,1%	90-180°	758 lm	26,7%
80-90°	256 lm	9,0%	0-180°	2842 lm	100,0%
90-100°	223 lm	7,8%			
100-110°	188 lm	6,6%	<b>BUG rating</b>		
110-120°	147 lm	5,2%		Lumen	% Total
120-130°	102 lm	3,6%	<b>Forward light</b>		
130-140°	60 lm	2,1%	Low(0-30°)	184 lm	6,5%
140-150°	28 lm	1,0%	Medium(30-60°)	431 lm	15,2%
150-160°	8 lm	0,3%	High(60-80°)	298 lm	10,5%
160-170°	1 lm	0,1%	Very high(80-90°)	128 lm	4,5%
170-180°	0 lm	0,0%	<b>Back light</b>		
<b>Total</b>	<b>2842 lm</b>	<b>100,0%</b>	Low(0-30°)	184 lm	6,5%
			Medium(30-60°)	431 lm	15,2%
			High(60-80°)	298 lm	10,5%
			Very high(80-90°)	128 lm	4,5%
<b>Intensity peaks</b>			<b>Uplight</b>		
Max intensity	455 cd		Low(90-100°)	223 lm	7,8%
Intensity, 90°	218 cd		High(100-180°)	536 lm	18,8%
Intensity, 0°	455 cd				

## IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

**BUG rating B1 U4 G2**



# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](#)

Operator:




## Power Details


### Input Power

Power feed to light source	20,8 W
Frequency of input power	50 Hz
RMS Input voltage feed, $V_{RMS}$	230 V
RMS Input current feed, $I_{RMS}$	0,099 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	22,88 VA
Displacement factor of AC power feed	0,99
Power factor of AC current feed	0,91
Total harmonic distortion of the current	40,75%
Total harmonic distortion of the voltage	0,07%

### Input Power Curve



### Efficiency



## Stabilization Details

### Warmup Conditions

Stable period	15 min
Stable change max	2,0%
Minimum time	15 min

### Color Temperature Change

CCT start	5968 K
CCT shift	+32 K
CCT end	6000 K


### Warmup Result

Total warmup time	Lamp stabilized in 15 min 3 sec
Warmup variation	-0,9%

### Output Change

Output start	2865 lm
Output change	-23 lm
Output end	2842 lm

### Stabilization Curve



# Light Measurement Report

Print date: 24-2-2025

Measurement date and time: 24-2-2025 16:00:54 – Measurement no. VFR-250224-0160-MS

Measurement tracking No. and Link: [VT250224-002255](#)

Operator:



## Flicker /TLA details

Flicker Meter Type: Viso Systems LabFlicker  
 Frequency of input power: 50 Hz  
 Flicker/TLA sample rate: 20000 samples/s

**Measurement time**  
 PstLM: 180 sec  
 All other indices: 1,2 sec

### Flicker indices according to Illuminating Engineering Society (IES)

Flicker frequency: 100 Hz  
 Percent Flicker: 1,26 %  
 Flicker index: 0

### Flicker indices according to California Energy Commission (CEC) 2016b

JA8/10 40 Hz: 0,01 %  
 JA8/10 90 Hz: 0,02 %  
 JA8/10 200 Hz: 1,31 %  
 JA8/10 400 Hz: 1,27 %  
 JA8/10 1000 Hz: 1,27 %


### TLA indices (re IEC TR 61547-1, IEC 61000-3-3 and IEC 61000-4-15)

PstLM value (F < 80 Hz): 0,01  
 SVM value (80 < F < 2000 Hz): 0,05


### Flicker indices according to Lighting Research Center (2015)

Perception metric, Assist Mp: 0

Flicker frame (frame of one flicker period in time domain)



Flicker FFT (flicker curve in frequency domain)



IEEE 1789 Frequency/modulation plot

